

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 142

Dated: 25-06-2025

It is certified that an inspection team headed by Dr. Ram Chandra, Senior Chemist
(Name of Officers with designation) from PHED Lab Jodhpur inspected the Alma Mater School,
103/5, 103/6, 103/7, 103/9, 103/10, Village Boranada, Tehsil Luni, Jodhpur, Rajasthan 342012 (Name &
Address of the school) on 24.06.2025 (date of inspection) and on the basis of Water Test
Report (Attached) bearing no Lab/Tech/Chem/25-26/142 dated 25-06-2025 of
PHED Regional Lab Jodhpur (PHEDLab) certified that the Alma Mater
School (Name of school) has safe drinking water facilities for the students and members of staff of the
institution. School is also maintains the hygienic sanitation condition in the school building & the campus
as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 23.06.2026 (one year)

Signature with Seal : (डॉ. राम चन्द्र)

Name : वरिष्ठ रसायनज्ञ

Designation : जन स्वास्थ्य अभियान्त्रिक विभाग

Name & Address of the Office/Department : प्रयोगशाला, जोधपुर

To

Principal
Alma Mater School
Village - Boranada
Teh. Luni, Jodhpur

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHEDLab/localbodies.



OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT,
REGIONAL LABORATORY-JODHPUR (RAJ.)

Email:- phedregionallabjodhpur@gmail.com

No. Lab/Tech/Chm./2025-2026/ 142

Date : 25-06-2025

TEST REPORT OF THE CHEMICAL EXAMINATION OF WATER

To,

PRINCIPAL

ALMA MATER SCHOOL

KHASRA NO. 103/5,103/6,103/7,103/9,103/10, VILLAGE BORANADA,

TEHSIL- LUNI

JODHPUR

**SAMPLE WAS NOT COLLECTED
BY THE LABORATORY**

Not for Legal Purpose

Reference: SP-1

Dated: 24.05.2025

District: JODHPUR

Sample Taker: DEEPAK KUMAR

Date of Reciept	23.06.2025
Date of Collection	23.06.2025
Date of Examination	25.06.2025
Source Type	R.O. WATER
Source Location	KHASRA NO. 103/5,103/6,103/7,103/9,103/10, VILLAGE BORANADA, TEHSIL- LUNI
City	JODHPUR
Lab Sample No.	PC-22

S. No.	Characteristics	Permissible Value as per BIS 10500/ 2012 Drinking Water Standards		Test Results
		Desirable Limit	Permissible Limit in absence of alternate Source	
1	pH @ 25 °C	6.5 to 8.5	No relaxation	7.30
2	Turbidity(NTU)	1	5	NIL
3	Colour	5	15	NIL
4	Odour	Agreeable	Agreeable	Agreeable
5	Temperature	----	----	-
6	Total Alkalinity (as CaCO ₃)	200	600	100
7	Total Hardness (as CaCO ₃)	200	600	120
8	Calcium (as Ca ⁺⁺)	75	200	33.60
9	Magnesium (as Mg ⁺⁺)	30	100	8.64
10	Chloride (as Cl ⁻)	250	1000	48
11	Sulphate(as SO ₄)	200	400	18
12	Nitrates (as NO ₃ ⁻)	45	No relaxation	10.00
13	Fluoride (as F ⁻)	1	1.5	0.11
14	Total Dissolved Solids (TDS)	500	2000	230

Remark:-


Superintending Chemist
P.H.E.D. Regional Lab., Jodhpur

No. Lab/Tech/Chm./2025-2026/

Date :

Copy to:

1. The Chief Chemist, Public Health Engineering Department-Rajasthan, Jaipur.

Superintending Chemist
P.H.E.D. Regional Lab., Jodhpur



**OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT,
REGIONAL LABORATORY-JODHPUR (RAJ.)**

Email:- phedregionallabjodhpur@gmail.com

No. Lab/Bact./2025-2026/ 143

Date : 25-06-2025

BACTERIOLOGICAL EXAMINATION REPORT

To,

PRINCIPAL

ALMA MATER SCHOOL

KHASRA NO. 103/5,103/6,103/7,103/9,103/10, VILLAGE

BORANADA, TEHSIL- LUNI

JODHPUR

SAMPLE WAS NOT COLLECTED
BY THE LABORATORY

Not for Legal Purpose

Refernce: SP-1

Dated: 24.05.2025

District: JODHPUR

Sample No.	Date of Collection	Date of Examination	Residual Chlorine mg./l	City/Village	Source Type	Particulars of Samples	Coliform Organism M.P.N. Per 100 ml
PB-03	23.06.2025 10.10 AM	23-06-2025	0	JODHPUR	R.O. WATER	KHASRA NO. 103/5,103/6,103/7,103/9,103/10, VILLAGE BORANADA, TEHSIL- LUNI	NIL


Superintending Chemist

P.H.E.D. Regional Lab., Jodhpur

No. Lab/Bact./2025-2026/

Copy to:

Date :

1. The Chief Chemist, P.H.E.D.-Rajasthan, Jaipur.

Superintending Chemist

P.H.E.D. Regional Lab., Jodhpur